



May 6, 2014

WIESER CONCRETE PRODUCTS, INC.  
MARK WIESER  
2815 RILEY ROAD  
PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS  
Manufacturer: WIESER CONCRETE PRODUCTS, INC.  
Product Name: SEPTIC/BIO-MICROBICS MICRO FAST 0.5/PUMP  
Model Number(s): WLP 550/450/650-FDL BIO 500  
[3-COMPARTMENT TANK; 500 GPD DWF; 1.05 LBS BOD5/DAY; 41.0 IN. L.L.;  
13.61/11.13/15.93 GAL./IN.; 96 IN. MAX. DEPTH OF BURY; TANK DIMENSIONS (OD) =  
160 IN. L X 72 IN. W X 57 IN. H]  
Product File No: 20140079

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of May 2019.**

This approval supersedes the approval issued on 7/20/2009 under product file number 20090255.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 500 gallons per day.
- This tank may ONLY be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- This product must be sized based on daily wastewater flow (gallons per day). The gallons per day value must be at least 150 gallons per day per bedroom.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan approval will take precedence.

WIESER CONCRETE PRODUCTS, INC.

Page 2

May 6, 2014

Product File No: 20140079

- Also refer to the department's product approval stipulations for the sewage treatment apparatus, which may include: maximum daily wastewater flow, influent strength, maximum BOD5, and maintenance intervals.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S.  
POWTS Product Reviewer  
phone: (608) 267-5265  
fax: (608) 267-9723  
email: glen.jones@wi.gov